

GREEN-HOUSE

METAL SHOP
740 SF.
OCC. FACTOR-20
T40Z00=37
37 OCCUPANTS
31" X 2" = 17'4" EXIT WIDTH
36" PROVIDED - OK

VO-AG CLASSROOM
740 SF.
OCC. FACTOR-20
T40Z00=37
37 OCCUPANTS
31" X 2" = 17'4" EXIT WIDTH
36" PROVIDED - OK

CLASSROOM
740 SF.
OCC. FACTOR-20
T40Z00=37
37 OCCUPANTS
31" X 2" = 17'4" EXIT WIDTH
36" PROVIDED - OK

WOOD SHOP
740 SF.
OCC. FACTOR-20
T40Z00=37
37 OCCUPANTS
31" X 2" = 17'4" EXIT WIDTH
36" PROVIDED - OK

OFFICE

LOCKER ROOM

MECH. ROOM

TOOL CRIB

LOCKER ROOM

OFFICE

Troy Middle School

Current APs (4) ●

Proposed New APs (5) ●

CLASSROOM
840 SF.
OCC. FACTOR-20
T40Z00=42
42 OCCUPANTS
42" X 2" = 8'4" EXIT WIDTH
36" PROVIDED - OK

CLASSROOM
840 SF.
OCC. FACTOR-20
T40Z00=42
42 OCCUPANTS
42" X 2" = 8'4" EXIT WIDTH
36" PROVIDED - OK

CLASSROOM
840 SF.
OCC. FACTOR-20
T40Z00=42
42 OCCUPANTS
42" X 2" = 8'4" EXIT WIDTH
36" PROVIDED - OK

CLASSROOM
840 SF.
OCC. FACTOR-20
T40Z00=42
42 OCCUPANTS
42" X 2" = 8'4" EXIT WIDTH
36" PROVIDED - OK

CLASSROOM
740 SF.
OCC. FACTOR-20
T40Z00=37
37 OCCUPANTS
31" X 2" = 17'4" EXIT WIDTH
36" PROVIDED - OK

TMSAP3

TMSAP4

CLASSROOM
740 SF.
OCC. FACTOR-20
T40Z00=37
37 OCCUPANTS
31" X 2" = 17'4" EXIT WIDTH
36" PROVIDED - OK

GIRL'S

JAN.

BOYS

OFFICE

OFFICE

OFFICE

36"

36"

36"

36"

36"

36"